IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # REPAIR PIN # 4614-84-1537 DATE 11-16-11

OWNER KEVIN MCGUIRE APPLICANT: SAME PHONE: Home/Cell # 704-724-8417 Business #

SITE ADDRESS 132 TUSKARORA POINT / N OWNER / APPLICANT ADDRESS SAME

SITE DIRECTIONS BSR, TUSKAROORA TRAIL, TUSK POINT, ON R

SUBDIVISION TUSKAROORA POINT BLOCK / SECTION 1 LOT # 8 LOT AREA .698 AC DESIGN FLOW 480 L.T.A.R. .3

Septic Tank Ex. 1000 Gallons: STB Date

Pump Tank Gallons: P T Date

Pump Make Model Serial #

No. Nitrification Fields: 1 No. Lines 1 Linear Feet 80'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth —

☐ New System ☒ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: ADD 1 @ 80', 25%

Repair System Description:

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions ① ADD 1 @ 80' LINE ② SHUT OFF LINE THAT IS FAILING (TEMPORARILY)

INITIAL SITE SKETCH

480' TOTAL

OLDER LINES SATURATED

N

TUSK POINT

DRIVE WAY

HOUSE

WELL

AS BUILT SKETCH

1"=50'

FAILING LINE

NEW LINE

282'

REPAIR

40' 40' 40' 40' 40' 40'

REPAIR

SUNSIDE

CONNECTED HERE

272

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☐ ***IMPROVEMENT PERMIT*** *with plat ~~valid without expiration.~~ site plan valid 60 mo.* ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date

IMPROVEMENT PERMIT by: REHS Date 11-16-11

AUTHORIZATION TO CONSTRUCT by: REHS Date 11-16-11

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

Installed by: ROWAN SEPTIC TANK

OPERATION PERMIT by: REHS Date 3-8-12

Existing System Inspected by: REHS Date

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant