46 14846643 L 269 132 Sunstede Dr.

Date Issued 2/27/76

Serial No. 5686

IMPROVEMENTS PERMIT

LA No 10674

T C No 001-281-4K

Map Date 2-21-75

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Cole (LAST) Fred (FIRST) B. (MIDDLE)

ADDRESS OF OWNER 1611 Marlwood Circle, Charlotte, N. C. ZIP 28212

LOCATION OF LOT Off Powell Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO 269 BLOCK NO 6

MAP BOOK NO _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60Min./In. on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 10674. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Samuel Spencer Jr.
Environmentalist

John R Adkisson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-8-1-72

HEALTH DEPARTMENT'S COPY