
Date Issued 5 JULY 75 **Serial No. 1675** ICAR'S Permit No. 13831

T C No

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 13531, dated 4-26-75 and the permit shall be void and of no effect if the information provided in the application is not true or is misrepresented. All work shall be completed on or before 5 JULY 75, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate 6C

Liquid Capacity of Tank 1000 gal

Tank Construction Precast Concrete

Absorption and/or Nitrification Lines

Total Line Length 320 ft

Number of Lines 4 (12 x 55')

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Jones, Allen

LOCATION OF PROPERTY off Tuckaseegee Trail

This permit must be in accordance with all requirements as set forth in the Regulations of the Mecklenburg County Board of Health in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered unaccessible or can be used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Comments: Tank with baffel - 17" stone (DELLINGER)

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy