Date Issued 13 Jan 77

Serial No. 0430


ICAR(S) Permit No. 10987

T. C. No. CA1-2814-8

Map Date 3-21-75

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, ____Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 10987 dated 13-Jan-77 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 13 Feb 77, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate 60

Liquid Capacity of Tank 1500 gal

Tank Construction Precast Concrete

Absorption and/or Nitrification Lines.

Total Line Length 600' -150'

Number of Lines 6-4

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Scofield, M S

LOCATION OF PROPERTY Dallas Hf Rd

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments Absorption pit

Division or Section Head

G M Caughfield
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy