CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4803

FILE: 16248 DATE: 6/22/89

TC: 00-382.53 ☑ L ☐ CRT

SERIAL № 11945

Name of Owner Irwin Rynald Juris.:

Address of Property 16200 Bruns Rd

Inspection Data:

Tank Material

Total Length of Drainfield 204'

Number of Lines 3 @ 68'

Cover Depth 24"

Water Supply Source Well


Distance to Water Source 50'

Excavation Inspected 6/2/89

Tank(s) Inspected

Wash Line Inspected

High Water Alarm Inspected



Design: 1989 Repair CTR# 80

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☐ installed or constructed ☐ altered or repaired
☐ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☐ Certificate of Completion ☐ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS:

Judy J. Knox R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.