Serial No. 3573

Date Issued 25 Apr 73

ICAR(S) Permit No 5996

P.C. T. C No. 061-281-01

Map Date 24 Feb 72


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ____Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 5996 dated 10 Apr 73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 21 May 73 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 50

Liquid Capacity of Tank 1000

Tank Construction PC

Absorption and/or Nitrification Lines.

Total Line Lenght 300'

Number of Lines 3 (2½'x100'x17")

Distance from House 10'

Distance from Property Line 25'

Distance from Well 100'

NAME OF OWNER Gosling, William Marion

LOCATION OF PROPERTY off Sunbrook Trail (Section C) Lake Norman

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used

Comments: Erosion Cont. Q (Cont.)

Division or Section Head

M. L. Kirby
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO E-5-4-1-71

HEALTH DEPARTMENT'S COPY