
Date Issued 2 June 77 **Serial No.0798** ICAR (S) Permit No 11811

T C No 001-291-2,4,W

Map Date 6-4-76

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
### (Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 11811 dated 1-17-77 and this permit shall be void and of no effect if the information provided in the application is not true or erroneous. All work shall be completed on or before 3 July 77 after which date this permit shall be null and void




PLOT OF SYSTEM

Permeability Rate 60

Liquid Capacity of Tank 1500 gal

Tank Construction Precast Concrete

Absorption and/or Nitrification Lines

Trench Line Length 450 ft - 150 ft

Number of Lines 5-3

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Massey Jr., Charles C.

LOCATION OF PROPERTY off Powell Road

The system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered inspectable. Comments

**The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Division or Section Head

J M Reynolds
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired

EHD-5-76

Environmental Health Department's Copy