
Date Issued July 5th 1984 Serial No. 07367 ICAR (S) Permit No. 13112

T. C. No. 001-382-47

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 13112, dated 10-27-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before Aug. 7th 1984, after which date this permit shall be null and void.



PLOT OF SYSTEM BALMORAL DRIVE

Permeability Rate P.S. IVA

Liquid Capacity of Tank 1500 GAL

Tank Construction Pre Cast Concrete

Absorption and/or Nitrification Lines

Total Line Length 300 LIN. FT.

Number of Lines FOUR

Distance from House 5 FT

Distance from Property Line 10 FT

Distance from Well Keep 75 FT AWAY NOT IN YET

NAME OF OWNER WOODS, RAYMOND

LOCATION OF PROPERTY 16110 BALMORAL DRIVE

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

FOUR TRENCHES To be 75FT x 3FT x 12 inches - Hay or Straw Cover - Grade Ok's

Comments

B Hendricks
Division or Section Head

Ralph Miller
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy