Serial No. 2074

ICAR(S) Permit No. 2467

P.C. T C No. 001-281-02 #X

Map Date 9-1-70


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

✓ Install or Construct ___ Alter or Repair the individual septic tank waste-subsurface soil absorption effluent discharge as specified herein at the described location based upon the information supplied in application 2467 dated 12 July 71. This permit shall be effective as the authorization provided in the application for a period of 12 months from date of issuance after which time it shall be void.



Percolation Rate 60

Liquid Capacity of Tank 1000

Type of Construction FC

Total Length of Subsurface Lines 200'

Number and Size of Lines 4 (10'X75'X17")

Distance from House 15'

Distance from Property Line 30'

Distance from Well 100'

NAME OF OWNER Thompson, Ernest

LOCATION OF PROPERTY Off Lucknow Trail (60'X 160)

The requirements as set forth in the Regulations of the Mecklenburg [illegible] printing [illegible] A certificate of approval for the system can be obtained [illegible] upon satisfactory completion of the system.

Clark & Nicholson (Clark) Winston, N.C.

[illegible]

[illegible]

Environmentalist

Prior to the construction of the new system it must be signed by the division or a Registered Environmental Health Specialist in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

OWNER'S COPY