
INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21218 DATE: 7-15-86
PIC: 001-382-49 fl
SERIAL № 10173

Permission is hereby given to ✓ Install or Construct. _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 7-11-86. All work shall be completed on or before 8-15-86, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons
Liquid Capacity of Dosing Tank 1000 gallons
Tank Construction Lcc

Absorption and/or Nitrification Lines:
Trench Width 3 feet
Total Line Length 400 feet
Number of Lines 4
Depth of Stone 12 inches
Distance from House 5 feet
Distance from Property Line 10 feet
Distance from Well 250' feet

NAME OF OWNER Craig Schmidt
LOCATION OF PROPERTY 12633 Clairborne Dr.
Comments: 4 lines 3'X100'X12" stone

Division or Section Head

B. A. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

C of A (s) No. 21218

Date Issued 8-25-86 Serial 8825 PO T C. No 001-382-49

CK7

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Schmidt (LAST) Craig (FIRST) (MIDDLE)

Location of Property 21633 Christmore Rd.

Application Number — Permit Number —

Inspection Data:

Liquid Capacity of Tank 1500 + 1000 Tank Material PCC

Total Length of Drain Tile 400' Number of Lines 4

Depth of Filter Material 12" Cover Depth 12"-21"

Water Supply Source well Distance from Water Source 7 50'

Excavation Inspected 8-25-86 (DATE) Tank Inspected 8-25-86 (DATE)

Nitrification Field Inspected 8-25-86 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 1986, 1500 ST, 1000 DT, PI, 1200 SFT, 12", Cecil

B. R. Ferguson
Environmentalist

EHD-5-74

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

MECK COUNTY ENVIRONMENTAL HEALTH RECEIVED MAR 3 1986

OFFICE USE ONLY: FILE: 21218 TC: 001-382-49 40

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH RECEIVED FEB 19 1986

JOB LOCATION

① ADDRESS: 21633 (STREET NO) CLAIRBORNE DR (STREET) ② FILE:

③ CITY: LAKE NORMAN ④ TAX PARCEL NO: Map Book 17 Page 625

⑤ SUBDIVISION: Section 6 ⑥ LOT: ½ of #239 ⑦ BLOCK:

OWNER

⑧ NAME: Craig (FIRST) Wayne (MIDDLE) Schmidt (LAST)

⑨ MAILING ADDRESS: 2029 Hopedale Rd

⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28269

⑬ PHONE: (WORK) 704-370-0[illegible] ⑭ (HOME 704-332-1211

REQUEST

This request is for a(n):

⑮ ☒ New installation permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA


System will serve:

⑲ ☒ Residence ㉘ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type?

㉓ Maximum occupancy? 4-5 ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?



㉙ Accurately dimensioned plot

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉚ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed:

Date: 2/11/86

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY