4615805717

TYPE III

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Elliott DATE 4-23-81 PERMIT NO. 112

PHONE: Business _____ Home _____

LOCATION 1100 TR 1236 ~1½ mi on Rt. TR Catesby Lane on Rt. S. R. No. _____

SUBDIVISION NAME L. V. LOT NO. 145 SECTION OR BLOCK NO. 6

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay loam
Percolation Rate 30 mpi
Topography 10-15%
Depth to Water Table 6'+
Rock or other impervious formations none obs.

Lot Area .72 AC.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 2 rows panels
Sq. Ft. _____ Linear Ft. ~150
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by Wayne Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JAC

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 4-22-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold