IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Elliott DATE 10-24-80 PERMIT NO. 289

PHONE: Business _____ Home _____

LOCATION 7100 TR 1236 (Cates by Lane) about 1/2 mile on R on R TR S. R. No. _____


SUBDIVISION NAME Luke NORMAN LOT NO. 145 SECTION OR BLOCK NO. 6

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms	4	No. Bathrooms	3		
Garbage Disposal Unit	Yes (X)	No ( )		Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )		Percolation Rate	5 Min
Auto. Wash. Machine	Yes (X)	No ( )		Topography	2–10%
Site Suitable	Yes (X)	No ( )		Depth to Water Table	4+
				Rock or other impervious formations	None observed

Lot Area .72 Acre

X Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 16"

Water Supply: Individual (X)
Public ( )

5' from deck

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Charles M. Elliott

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: follow contours – Keep system as shallow as possible – Owner should not drive over system

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold