IREDELL COUNTY HEALTH DEPARTMENT

APPENDIX H

SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: Charles Elliott DATE REQUESTED: 10-29-80

ADDRESS: PLAT NO.:

COUNTY: Iredell LOT SIZE: .7 Acre Valley Lot #45

LOCATION OF SITE: 1100 ft R 1236 abt 1/2 mile on R Catesby Lane ON R

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-10% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S PS clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey soils)	S PS Sub Angular U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	S PS None Observed U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS No Mottles U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS 80 mpi U	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION*	PS			
SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

Recommendations/Comments: See Comments on plan.

Described By: Fred Clement

Title: S-I Date: 10-29-80

DHS Form 2601 (2/77)
Sanitation