DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mark Weigel
ADDRESS: ____
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): 480gpd
LOCATION OF SITE: ____

APPLICATION DATE ____
DATE EVALUATED: 1-8-07
PROPERTY SIZE: ~1 1-19-07
PROPERTY RECORDED: ____

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	8% D	0-12	1sbk cl		few yel/br @40" looks like root area	48			.3
		12-36	1sbk c	fr ss/sp se					
		36-48	1sbk cl						
			dug after heavy rain						
			water seeping in @ 36"						
2		0-18	1sbk/sbk c	fi		48			.3 18-48
		18-48	1sbk c	fr ss/sp se					
			old driveway						
3		0-48	1sbk c	fr ss/sp se		48			.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	NO
System Type(s)	LPPanel	Plat bk 14
Site LTAR	.3	Pg 22

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J Melville
OTHER(S) PRESENT: ____

COMMENTS: system designed below profile #1
1976 area delineated