DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Roger Freeman OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 8/9/94
PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE: ___
LOCATION OF SITE: SR 1336 on Rt ~1/4 mile past Fawn Lane
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1		0-12	SAB / CL				PS		.4
		12-36	SAB / C						
		36-43+	WK SAB / SIC						
		43-48	Saprolyte						
2									
3									
4									
5									

AVAILABLE SPACE (%): 95 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .4
EVALUATED BY: DRRobinson RS OTHER(S) PRESENT: ___
COMMENTS: Owner desires to install PPBPS to accomodate more desirable house location