WHITE HORSE

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C.W. Brewer DATE 10-7-96 PERMIT NO. 278

PHONE Business _____ Home 537-0843

LOCATION Hwy 115 TR on 11TH TL on 145 ½ mi. on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 99 SECTION OR BLOCK NO. 7

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3 Acre


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Not to be taken

Topography 2 to 5% slope

Depth to Water Table 6 to 8' to Lake level

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 625 Linear Ft. 250'

Depth of Stone in Lines 18"

Water Supply: Individual (✓)
Public ( )

Installed by R. J. Brewer
Charlotte, NC

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY H. C. Moore DATE 10-7-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold