4615 89 9366

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147076 PIN# 4626 11 5224.641 DATE 8/8/08

OWNER OR APPLICANT Mid Atlantic Cons. Bldrs. PHONE: Business 704-202-5568 Home

ADDRESS PO Box 3792 Mooresville NC 28117

LOCATION 1100 TR Churchwood TL 1st Berber Loop Lot on R past Old Autoway

SUBDIVISION Waterline Landing BLOCK / SECTION LOT 41 LOT AREA ~.8 Ac SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .275

Septic Tank: 1000 Gallons; ST# 794 Date 6/10/08

Pump Tank: 1000 Gallons; PT 283 Date 7/14/08

Pump Make: Gerilds Model WG05 AH Serial No.

Nitrification Field: No Fields 1 Square Feet 945 Linear Feet 315

No Lines 6 Trench Width 3' Max Trench Bottom Depth 3'

[X] New System [ ] Repair [ ] Expansion System Type: I II III (IV) V VI

System Description: LPP BPS

Repair System Description: SAME

Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 4

[ ] Mobile Home No. Persons

[ ] Business No. Employees

[ ] Other

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth No [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: SIMTECH FILTER REQUIRED. Fast Track Specs and Design by Rollens Environmental 704-658-1723.

Comments:/Conditions: 8/25/08 Approved initial system in Repair Area - WS.

INITIAL SITE SKETCH

(1) Installer must have layout & specifications on site during installation of this system.

(2) TDH 4466 + 30 GPM Pump Specifications

AS BUILT SKETCH

Drainlines checked 9/19/08

Valve box & pressure checked 10/7/08

Electrical checked 10/27/08

Maintenance ~~Agr~~

See changes made on site plan Rec'd 10/27/08

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X _____ date 8/19/08 Installed by: Russell Williams

Improvement Permit by: Wesley Sparks R.S. date 8/8/08 Operation Permit by: Anthony Cohen R.S. date 10/27/08

Authorization to Construct by: Anthony Cohen R.S. date 9/18/08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK