IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147075 PIN# ~~4626 HF 324.040~~ 4615 89 9662 DATE 8-11-08

OWNER OR APPLICANT Mid-Atlantic Custom Builders PHONE: Business 704-202-5568 Home

ADDRESS PO Box 3792 Mooresville NC 28117

LOCATION 1100, TR Chuckwood, TL Barber Loop, on R

SUBDIVISION Watertree Landing BLOCK / SECTION LOT 40 LOT AREA .95Ac SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 794 Date 10/08

Pump Tank: 1000 Gallons; PT 27 Date 10/08

Pump Make: Gouras Model PE-SIM Serial No.

Nitrification Field: No Fields 1 Square Feet 1440' Linear Feet 480'

No Lines 4@120' Trench Width 3' Max Trench Bottom Depth 3'

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM - 25% Red.

Repair System Description: LP - PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth — ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: In-line filter required in pump tank

Comments:/Conditions: Heelog - Lines Par.

INITIAL SITE SKETCH

See Attached plan From Rollins Soil + Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 8-18-08 Installed by: Russell Williams

Improvement Permit by: date 8-11-08 Operation Permit by: Wesley Sparks RS. date 5/5/09

Authorization to Construct by: date 8-11-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK