Paid $500 5-13-13

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 175416

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4615 92 0217

APPLICANT: Mike Athanas APPLICANT ADDRESS: 1999 Candlewick Dr Fort Mill SC 29715

SITE ADDRESS: 169 Fawn Lane Mooresville 28117 PHONE: 704-576-3887 ALT. PHONE:

SITE DIRECTIONS: Brawley Sch Rd TR Stonemarker TR Fawn on Left

SUBDIVISION: CL&T SECTION: 6 LOT # 121 LOT AREA: 1.6 Ac DESIGN FLOW: 480gpd L.T.A.R.: .3gpd/ft²

Septic Tank 1000 (gal) STB 1060 Date
Pump Tank 1000 (gal) PT 1060 Date
Pump Make GOULDS Model WE05 1ZHHU Serial #
Nitrification Fields 1 # Lines 8 Linear Ft: 269
Trench Width 24" min. Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III ⓘ V VI
System Description: LP PPBPS
Repair System Description: Pre-treat TS II PPBPS
Maintenance Agreement Required: ☒ YES ☐ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Abandon well closest to house before AC supply line 5' from foundation 10' from basement Properly abandon existing system

INITIAL SITE SKETCH

See Plan From
Michael Athanas
+ Associates
Approved by ICHD

AS BUILT SKETCH

CHECKED TANKS BA CHECKED LINES BA
12-12-13
SET PH(2') 1-17-14
ELECTRICAL CHECKED

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 5/13/13 Installed by: Roddi Lowe Grading

IMPROVEMENT PERMIT by: Andy Melville Date: 4-3-13 OPERATION PERMIT by: Date: 1-27-14

AUTHORIZATION TO CONSTRUCT by: Andy Melville Date: 4-3-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK