DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wyatt Clark
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): 480 DATE EVALUATED: 8-1-06
LOCATION OF SITE: CL&T # 115 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	LgrSL			46+			.3
		4-30	lSbkCl						
		30-40	lSbkC						
		40-46	lSbkCl						
		46	lt gravel	couldn't auger					
2		0-8	lSbkCl			48			.3
		8-36	lSbkC	fr SS/SpSS					
		38-48	lSbkCl						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	25% red.	LP Panel
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1938): PS
EVALUATED BY: J. Melville
OTHER(S) PRESENT: _____

COMMENTS: _____