4616805075

Gave Crescent Approval 3-26-80

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul Monday for F.H. Funke DATE April 11, 1979 PERMIT NO. 91

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1177 T.L. on 1458 1mi. on Rt.

S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 96 SECTION OR BLOCK NO. 7

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	6-60
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	sink.
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none obs.
			Rock or other impervious formations	

Lot Area 3/4 AC.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Area surrounding nitrification field needs to be landscaped and surface water diverted away.

CERTIFICATE OF COMPLETION BY Harold R. Hinson DATE April 11, 1979

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold