DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH


SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Happy DeJong / Terry Waggoner OWNER: ___ AGENT: ___ PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 9/23/14
PROPOSED FACILITY: 3 bedroom SF dwelling, Basement
PROPERTY SIZE: .189 ac
LOCATION OF SITE: Sect 7 lot 92, Crescent Resources off Barber Loop
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1		0-3	gr sab scl	1:1 / efi-dry			PS		.3
		3-8	wk sab - c	1:1 / efi-dry-compacted					
		8-17	sab - c	1:1 / fi-vfi					
		17-34	wk sab - sic	1:1					
		34-48+	wk sab - sicl - saprock.						
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: DC Hamm, RS OTHER(S) PRESENT: Terry Waggoner
COMMENTS: Options to be considered 1) Apply for 2 bedroom (space very close), 2) look a house placement adjustment to either use existing system or free area on point side for new installation, 3) Reduce footprint of house


50'
50'
Shallow soil
10'
50'
25'
50'
Proposed Basement Area
50'
EX Well
Proposed Driveway
AREA OF EX. SYS