4616903483

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 14752 PIN # ~~4626115224.054~~ DATE 4-24-2009

OWNER or APPLICANT Mid Atlantic Builders Inc PHONE: Business Home:

OWNER or APPLICANT ADDRESS P.O. Box 3792 Mooresville, NC 28117

LOCATION / DIRECTIONS Brawley School Rd TR Chokkumed take to end TL Barber Lp lot on left

SUBDIVISION Watertree Land BLOCK / SECTION LOT # 54 LOT AREA 30,145sf DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank 1000 Gallons: STB 744 Date 1-27-09

Pump Tank Gallons: PT Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 425'

Trench Width 36" Max. Trench Bottom Depth 36"-48" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: Gravity - 25% Reduction

Repair System Description: Pump-Lp - 25% Reduction

Maintenance Agreement Required ☐ YES ☒ NO Not initially

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: ~~X~~ Note: Maximum trench depth of upper trench is 48" (Soil verified in Pit) 36" lower trench. Soil/Site evaluation performed by Rollans Soil & Environmental Services

Comments / Conditions: Installed Quick 4 For Drainfield Red Filter Used

INITIAL SITE SKETCH

See Attached/Approved plan by Rollans Env.

AS BUILT SKETCH

Installed 3 lines @ 74'

2 @ 90'

Total = 402 ft

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 4/27/09

Improvement Permit by: Date 4/24/09

Authorization to Construct by: Date 4/27/09

Installed by: Russell Williams

Operation Permit by: Date: 4/27/09

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant