4616903666 V

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy J. Lentz DATE 12-28-16 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 18 to Hiddenbrook Rd to Lake Norman Rd to Barber Loop Rd

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 89 SECTION OR BLOCK NO. 7

503 Barber Loop Mrsvl

House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil Clay Loam

Garbage Disposal Unit Yes (X) No ( ) Percolation Rate Perk Test


Auto. Dishwasher Yes (X) No ( ) Topography Rolling Slope

Auto. Wash Machine Yes (X) No ( ) Depth to Water Table 10 Ft

Slab Shingle Yes (X) No ( ) Rock or other impervious formations None

Lot Area 1.5 Acre

Lake



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 20"

Water Supply: Individual (X)
Public ( )

Installed by E. J. Evans

IMPROVEMENTS PERMIT BY [signature]

COMMENTS

CERTIFICATE OF COMPLETION BY [signature] DATE 12-28-16

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White - Inspection Dept. Copy: Yellow - Sanitarian's Copy: Pink - Owner's Copy: Gold