4616 907 099

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tommy Smith DATE 10-3-24 PERMIT NO. 270

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1100 1mi TL on 1459 2 mi on left S. R. No. 1459

SUBDIVISION NAME Lake Norman LOT NO. 114 SECTION OR BLOCK NO. 01

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Lot Area Level


Character & Porosity of Soil Fine Sandy Clay loam Porosity Fair

Percolation Rate 30 min per inch

Topography Slope

Depth to Water Table 4 ft to lake level

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft. 250

Depth of Stone in Lines 24"

Water Supply: Individual (✓)

Public ( )

Installed by Tolan Rawls

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-9-24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold