IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Houser DATE 3-14-22 PERMIT NO. 38

PHONE: Business 873 4660 Home

LOCATION 1100 TR on 1177 after 7 Log 1458 1.4 mi to right at end

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 82 SECTION OR BLOCK NO. 7

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 10,824


Character & Porosity of Soil Sandy Clay loam Fair

Percolation Rate Soil Boring

Topography 2 to 5% slope

Depth to Water Table 6 ft. B Rock

Rock or other impervious formations



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by E.S. Erwin

IMPROVEMENTS PERMIT BY John Faucette

COMMENTS

CERTIFICATE OF COMPLETION BY John Faucette DATE 5-19-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold