PIN 4616979033

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Kincaid Homes DATE 11-1-07 PERMIT NO.

PHONE: Business Home 663-2430

LOCATION 1100 - 72 on 1115 Turn on 1455 3rd drive on left

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 216 SECTION OR BLOCK NO. 5A

794 Lakeview Shores Dr

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre


Character & Porosity of Soil Clay loam

Percolation Rate 5 soil 15 rock

Topography 2% Slope

Depth to Water Table 6 to 8'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 225 Linear Ft. 350
Depth of Stone in Lines 14"

Water Supply: Individual (✓)
Public ( )

Installed by T. R. Rawls

The proposed / existing Deck replacement addition does not appear to impact the existing septic system.
**NOTE: Must stay at least 5ft from Septic & 25ft from well

Wayne Dotson R.S.
Date: 11/7/2012
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Existing System is adequate for new house

CERTIFICATE OF COMPLETION BY K. C. Moore DATE 11-1-07

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold