DELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 315.00 Paid MOORESVILLE 704-664-5281 11/20

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13145 PIN# 4626 07 1828.469 4616-97-9925 DATE Sept 29, 05

OWNER OR CONTRACTOR The Farms, LLC / Whitley PHONE: Business Home

ADDRESS 2214 Brawley School Rd Mooresville, NC 28117

LOCATION Brawley School Rd TR McKendree TR Spears Creek DR. at end on Right

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 469 LOT AREA .781 Ac SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .25

Septic Tank: 1000+ Gallons; STB 338 Date 9-2-07
Pump Tank: 1000 Gallons; PT 27 Date 9-05-07
Pump Make: Zoeller Model 140 Serial No.
Nitrification Field: No Fields 1 Square Feet 640/960 Linear Feet 320
No Lines 4 (CF) Trench Width 24" min 8'oc Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: LPP PBPS
Repair System Description: LPP PBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms
☐ Business No. Employees
☐ Other
☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: 36" MAX 8'oc

Critical site evaluation and system design performed by Paul Pennington and Kathleen Hawk of S&ME

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments:/Conditions: 11/5/07 okay to end feed Drainlines
Plumbing Stubbed out on opposite side.
11/8/07 Checked tanks & lin
11/20/07 Pres, Efeat & alarm Checked

AS BUILT SKETCH

Installed Essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit without valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Hawk date 9/30/05 Installed by: K & H RS

Improvement Permit by: D.R. Turner RS date 9-29-05 Operation Permit by: Marian H. Dotson RS date 11/20/07

Authorization to Construct by: Judy McNeill date 6-20-06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK