4616981116

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

NER OR CONTRACTOR Marvin Sackett DATE 11/7/85 PERMIT NO. 207

IONE: Business _____ Home _____

LOCATION 1100, Rt on 1115, Rt on 1455 (2nd Lake View Drive) Go 1/2 mi Lf at Short curve befor pavement ends, at end on point S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 228 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other Repair Adding Garage w/ Plumbing

No. Bedrooms 2 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Existing	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
Lot Area Existing			Rock or other impervious formations		

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Add New 100 ~~1,750 gal Box~~ Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Harry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Old Tank w/Baffle Filled w/Dirt by Harry Beam (Old Well Property Abandoned) Keep new well 50' from Systems

CERTIFICATE OF COMPLETION BY Kelly Sheeks & J.C. Moore DATE 4-21-86

STING SYSTEM CHECKED BY: _____ Checked To See Well was abandoned DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making ments Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold