DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Rick Jasinski OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10/20/94
PROPOSED FACILITY: 4 bedroom
PROPERTY SIZE:
LOCATION OF SITE: Parkerway Dr.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	SS 2%	0-18	SAB / CL	1:1 / fr-fi			PS		.4
		18-48	SAB / C	1:1 / fi-vfi			PS		.3
2	SS	0-8"	SAB / scl	1:1 / fi			PS		.5
		8-20	SAB / C	1:1 / vfi					.4
		20-43+	WK SAB / SiC	1:1 / fi					.3
3									
4									
5									

AVAILABLE SPACE (.1948): 4 SITE CLASSIFICATION (.1948): 4 SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: DBJ OTHER(S) PRESENT: Rick Jasinski
COMMENTS: Site can be reclassified PS per rule 1956 - modified system
PPBPS