IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Arthur E Hartley DATE 6-1-20 PERMIT NO. 101

PHONE: Business _____ Home 312 2nd Ave

LOCATION 1100 ft on NC 115 to 2 - left

_____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 244 SECTION OR BLOCK NO. 8


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 2 to 8%
Depth to Water Table 4 to 8
Rock or other impervious formations None

Lot Area 3 Acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 400 Linear Ft. 200
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by J. E. Faulk

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Joshua Hamilton DATE 6-1-20

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold