
4624052016 L373 105 Twigg Lane

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2137-A DATE: 10-23-86
TC: 001-391-98 pd
SERIAL № 10494

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 6-19-86. All work shall be completed on or before 11-23-86, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



LOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons
Liquid Capacity of Dosing Tank 1000 gallons
Tank Construction PVC

Absorption and/or Nitrification Lines:
Trench Width 15 feet
Total Line Length 400 feet
Number of Lines 5
Depth of Stone 17 inches
Distance from House 5 feet
Distance from Property Line 5 feet
Distance from Well 50 feet

NAME OF OWNER Henry Wells
LOCATION OF PROPERTY 2146 Twigg Ln.
Comments: Used 15'X80'X17" Stone, grade boards, straw cover Install a riser on 1500 and 1000 tanks. Divert surface water. Two inch PVC supply line, 25 ft. from well

S. W. Adkinson — Division or Section Head
D. R. Ferguson — Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY