CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21594 DATE: 3/18/94

TC: 001 38239 ☐ L ☐ CRT

SERIAL NO 1555

Name of Owner Richard Mcwhirt Juris.:

Address of Property 1613 Belmont Dr

Inspection Data:

Tank Material 1500

Total Length of Drainfield 60'

Number of Lines 4 @ 10'

Cover Depth 5

Water Supply Source Public well


Distance to Water Source 90'

Excavation Inspected 3/18/94

Tank(s) Inspected 3/18/94

Wash Line Inspected --

High Water Alarm Inspected --



Design: 3BR (1000 Gal, Conv, 20x550 ft Trench Bed) CTR#

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☒ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Septic system designed for 3 bedroom residence

Phillip A Walker R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.