4624095383

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frank Wilhelm DATE 11/16/79 PERMIT NO. 392

PHONE: Business _____ Home _____


LOCATION 1100, TR 1236, Bear to left and then immediately to R at forks 1/4mile on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 170 SECTION OR BLOCK NO. 6

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~ 3/4acre

Character & Porosity of Soil Clay loam
Percolation Rate 80 cpi
Topography 8-10 %
Depth to Water Table unknown
Rock or other impervious formations NONE OBSERVED



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Cremer

IMPROVEMENTS PERMIT BY David R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 11/16/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold