IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Gray DATE 8-30-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Road 1100 TR on 1236 1mi on right

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 86 SECTION OR BLOCK NO. 6

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area .91 Acre


Character & Porosity of Soil Clay loam

Percolation Rate 45 m/ 1 inch

Topography 8% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 17 to 24"

Water Supply: Individual (✓)
Public ( )

Installed by John Howie

-Ditch
7'X100'
2 line

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-30-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold