DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____


SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Philip Turpin OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: 3/16/92 DATE EVALUATED: 3/20/92
PROPOSED FACILITY: 4 Br 3½ Ba House
PROPERTY SIZE: ≈ 1 acre
LOCATION OF SITE: Lot 85 Stonemarker
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	≈10%	0-2	Organic/Sandy		—	—	—	—	—
		2-34	1:1 Cly SAB		None	None	PS		~0.3
		34-42	Cly/Saprolite Mix		None	None	PS		~0.3
2	≈10%	0-6	Organic/Sandy		None	None	PS		~0.3
		6-42	1:1 Cly SAB						
3	≈10%	0-2	Organic-Sandy Cly		None	None	PS		~0.3
		2-42	1:1 Cly SAB						
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.2
EVALUATED BY: ICan OTHER(S) PRESENT: Philip Turpin

COMMENTS:
Conv. PPBPS on lake side, House moved back 95' from 70 contour


Lake
2
1
Exist mlti
3
DRIVE
Well
Stonemarker