IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 113616 PIN# 4624-16-2297 DATE 10/19/05

OWNER OR APPLICANT ~~Ingrid Hoyt~~ Dick & Muriel Dyer PHONE: Business _____ Home _____

ADDRESS 207 Gainswood Dr Mooresville NC 28117

LOCATION BSR TR Tuskaroras, on Lt before Estes Park

SUBDIVISION Lot BLOCK / SECTION 6 LOT 1730 LOT AREA 0.891Ac SITE CLASS PS DESIGN FLOW 360 L.T.A.R. 0.5

Septic Tank: 1000 Gallons: STB 312 Date 10-12-06
Pump Tank: 1000 Gallons: PT 253 Date 11-27-06
Pump Make Gaulds Model WE0312M1 Serial No. _____
Nitrification Field: No Fields 1 Square Feet 600 Linear Feet 200
No Lines 2@100' Trench Width 24" or 36" Max Trench Bottom Depth 36" Gravel Depth _____

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LA Quel Block
Repair System Description: Same
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 3 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community


☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing


Comments/Conditions: 80oc or 95oc

Do not Cut House Site - Back fill for Positive Drainage

Comments/Conditions: Checked tanks 11/29/06 MD
Checked lines 11/30/06 MD

INITIAL SITE SKETCH





The proposed / existing Dining Room Addition addition does not appear to impact the existing septic system.
**NOTE: Must stay at least 5FT From Septic & 50ft to lake
Maria Dolan REHS
Date: 9/13/2011
ICHD-Environmental Health Division

The proposed / existing Garage addition does not appear to impact the existing septic system.
**NOTE: _____
Judy Melville R.S.
Date: 5-22-12
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the s
Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Ingrid Hoyt date 10/19/05
Improvement Permit by: _____ RS date 10/19/05
Authorization to Construct by: _____ RS date 3/16/05

Installed by: K & H RS
Operation Permit by: Maria Dolan date 1/3/07
Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK