Date Issued 4-26 74 Serial No. 5135 ICAR(S) Permit No 6680

AOI C No 001-281-01

Map Date 3-24-72


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to Install or Construct Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 6680, dated 3-20-73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 26 May 74, after which date this permit will be null and void



PLOT OF SYSTEM

Percolation Rate

Liquid Capacity of Tank 1000 gal

Tank Construction PC

Absorption and/or Nitrification Lines

Total Line Length 300'

Number of Lines 5 (12½ x 60 x 17")

Distance from House 10'+

Distance from Property Line 10'+

Distance from Well

NAME OF OWNER Hilda Smith

LOCATION OF PROPERTY Tuskarora Trail

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used

Comments Aeration unit 8½ x 7' x 4'6" Stone
Evans Contractors

Division or Section Head

Environmentalist

If this permit is for the installation or construction of a new system it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired

Form E-5-9-1-72