Date Issued 10-2-85 Serial No. 08567 ICAR(S) Permit No. 19002


T. C. No. 001-382-07

Map Date 1

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application ~~Heth~~, dated 09-12-85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11-2-85, after which date this permit shall be null and void.

REPAIR



PLOT OF SYSTEM

Permeability Rate ___

Liquid Capacity of Tank ___

Tank Construction ___

Absorption and/or Nitrification Lines:

Total Line Length 100'

Number of Lines 2 x 50'

Distance from House 5'

Distance from Property Line 10'

Distance from Well 50'

NAME OF OWNER HINKLE, JOHN M

LOCATION OF PROPERTY 1616 BLARNEY RD

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

2 line x 50' long - 3' wide x 17" stone

Comments: ___

Division or Section Head

Kelly Randall
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHB-5-76

Environmental Health Department's Copy