IREDELL COUNTY HEALTH DEPARTMENT


ENVIRONMENTAL HEALTH DIVISION

PAGE 2: *SITE PLAN WORKSHEET*

SEE THE "SAMPLE SITE PLAN" BELOW. INCOMPLETE SITE PLANS WILL BE RETURNED TO YOU FOR COMPLETION AND MAY RESULT IN A DELAY IN THE ISSUANCE OF YOUR SEPTIC SYSTEM PERMIT!!!

Place an (X) beside each item as you complete the site plan:

( ) Property Line measurements are clearly identified
( ) All proposed structures are indicated
( ) Front and side setbacks from property line
( ) Preferred driveway location and well location
( ) Area you prefer your septic system to be placed
( ) North arrow, or other sufficient indicator of direction




Circle N/A on the following if appropriate:

Location of septic systems and wells within 100' of your property	N/A
Location of easements and rights of ways on your property	N/A
Location of any designated wetlands on the property	N/A

USE THIS SPACE TO DRAW YOUR SITE PLAN

Show: proposed house or business footprint, wells, water lines, patios, pools and decks, and any other item that will occupy space on the site



Signature: Tab Howell

Property owner or owner's legal representative signature (SIGNATURE REQUIRED)

9-23-15

DATE

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W.R. Whitlow DATE 6-13-74 PERMIT NO. 158

PHONE: Business _____ Home _____


LOCATION 1100 TR on Rd 1236 at mecklenb. line Turn at next left then TR 1000' on left S. R. No. 1236

SUBDIVISION NAME Lake Norman LOT NO. 173 SECTION OR BLOCK NO. 6

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	C/L/y loam Porosity Fair to P
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	58 min/ inch
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	20% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	8 to 10' above lake level
Lot Area ½ acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Godwin
Charlotte, NC

8/20/14 SE

75' Long
7.5' wide ✓

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Ditch had 12" of fall so constructed a concrete dam half way down to hold effluent back to work over entire ditch.

CERTIFICATE OF COMPLETION BY J.C. Moore DATE 6-17-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

DAS DON ALLEN & ASSOCIATES, P. A.
"Since 1971"
Commercial * Residential * Mortgage Surveys * Multi-Family
Construction Staking * Subdivision Design * Topographical
111-B Raceway Drive * Mooresville * NC * 28117
(704) 664-7029 (704) 664-8041 Fax


I, certify that this map was drawn under my supervision from an actual survey made under my supervision recorded in deed book 2333, page 2060, and/or plat book 14, page 26, that the ratio of precision is 1':10,000, that this map was prepared in accordance with the General Statutes of North Carolina Chapter 89C. my hand and seal on the 26, day of MARCH, A.D. 20 15

WILLIAM M. ALLEN

NORTH CAROLINA PROFESSIONAL SEAL L3499 LAND SURVEYOR WILLIAM M. ALLEN

186 86 53

CURVE TABLE				
CURVE	RADIUS	LENGTH	BEARING	CHORD
C1	292.74'	32.22'	S 86°30'56" E	32.21'
C2	317.04'	15.77'	N 87°51'24" W	15.77'



NOTES
1) THIS PROPERTY MAY BE SUBJECT TO ANY EASEMENT AND/OR RIGHTS-OF-WAY OF RECORD.
2) AREA COMPUTED BY THE COORDINATE METHOD.
3) EXISTING 760' & 761' CONTOUR ELEVATION BASED ON LAKE NORMAN LAKE LEVEL AT COWAN'S FORD DAM (READING ON 8\26\14) ELEVATION: 757.10
4) UNDERGROUND POWER
5) NO GRID MONUMENT FOUND WITHIN 2000 FEET.

LEGEND
P.P. = POWER POLE
= DUKE POWER TRANS.
E.I.P. = EXISTING IRON FOUND
I.P.S. = #4 REBAR SET
R/W = RIGHT-OF-WAY
(W) = WELL

0' 25' 50' 100'
SCALE IN FEET

FOUNDATION SURVEY

OF
676 STONEMARKER RD
LOT 173 CRESCENT LAND & TIMBER CORP., SECT. 6
DAVIDSON TWSP., IREDELL CO., N.C.
JUDY W. MURPHY & MARGARET W. HOWARD

SCALE 1" = 50'
ACQUIRED BY:

FIELD BOOK: 500E
FILE: CLT 173 SECT 6
DC FILE:
TAX MAP NO: 4824190107