4624192423

11452

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy Bonham DATE 8/7/90 PERMIT NO. 2D-1-A-178

PHONE: Business _____ Home 521-9281

LOCATION Stonemarker SR 1236

S. R. No. _____

SUBDIVISION NAME Stonemarker LOT NO. 1 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Stonemarker

Character & Porosity of Soil Ps clay


Percolation Rate ~ 0.35

Topography 1-10%

Depth to Water Table +3'

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Stonemarker

IMPROVEMENTS PERMIT BY _____

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345'

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

COMMENTS: PVC tee in place of precast tee

CERTIFICATE OF COMPLETION BY Sam Ingram E.H.S. DATE 8/7/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold