DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION

OWNER: Kris Kozdras APPLICANT: _____
ADDRESS: 262 Stonemark APPLICATION DATE: _____ DATE EVALUATED: 9/13/2001
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Panel
5 Bdrm Initial & Repair

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-18"	Brw SCL	GR FR	m-wSBK	SS, SP, SE, FI-FR			PS .3
		18"-48"	Rd/Brw C/CL						
2	Public	0-13	Gravel/Coarse sand						PS .3
		13-24	Brw SCL	GR FR	m/wSBK	SS, SP, SE, FI-FR			
		24-58	Rd to Rd/Brw C/CL	Common Mica Flakes & Few SAP Inclus					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Usable Space (.1945)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____