DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jeff Hunt
ADDRESS: 1061 RT 376 Wappingers Falls NY 12590
PROPOSED FACILITY: R.S.
LOCATION OF SITE: lot 437 Clot Sec 6
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☑ Pit ☐ Cut

PROPOSED DESIGN FLOW (.1949): 600
APPLICATION DATE 8/10
DATE EVALUATED: 8/10
PROPERTY SIZE: ~ 1 AC
PROPERTY RECORDED: ___
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
AB 1	LSS 0-5%	0-26	RC MFSBK	fri SSSP SxP	—	48"	—	—	.3
		26-48	RCL WSBK	fri SSSP SxP					
P 2	LSS 5-10%	0-15	RC MFSBK	fri SSSP SxP	—	40"	PS	—	.3
		15-40	RCL WSBK	fri SSSP SxP - common SAP					
		40-60	SLSAP M	fri SSSP SxP					
P 2 3	LSS 5-10%	0-10	Fill		—	31"	PS	—	.3
		10-20	RC MFSBK	fri SSSP SxP					
		20-31	RCL WSBK	fri SSSP SxP - common SAP					
		31-60	SLSAP M	fri SSSP SxP					
4	5% L	0-24	MFSBK	fr SS SxP	—	48"	N/A	—	.3
		24-48	MFSBK	fr SS SxP few SAP mica					
	5% L	0-28	RC MFSBK	fri SSSP SxP					
		28-48	RCL WSBK	fri SSSP SxP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPBPS	Pretreatment LPPBPS
Site LTAR	.3	.3

COMMENTS: ___

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: MICHAEL ATHANAS & ASSOCIATES
OTHER(S) PRESENT: #4 Brady, Judy M.

Approved 8-30-10 ICHD