4624215844 153 Points End Dr.

2447

Date Issued 5-29-84

Serial No. 07256


ICAR(S) Permit No. 21100

T C No 001-361-30

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, Y Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21100, dated 5-25-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before JUNE 30, 1984 after which date this permit shall be null and void.



Permeability Rate PS IDA

Liquid Capacity of Tank 1500 gal

Tank Construction Pre Cast Concrete

Absorption and or Nitrification Lines

Total Line Length 100 Lin FT

Number of Lines Two

Distance from House 10FT

Distance from Property Line 10FT

Distance from Well 7 50 FT

NAME OF OWNER LEVENTIS, GEORGE

LOCATION OF PROPERTY 21320 MAYHEW ROAD

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

NEW TANK IF LOWER THAN DIST BOX OR DRAINFIELD - AND TWO TRENCHES 50 FT x 2 FT x 18 in. deep - AND DIST BOX

Comments:

B. Hunter
Division or Section Head

Ralph Miller
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy