1200

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 161343 PIN # 4624-23-0757 DATE May 28, 2010

OWNER or APPLICANT Ronnie Thompson / Joey Davis PHONE: Business 704-905-7582 Home:

OWNER or APPLICANT ADDRESS 134 Southpoint Dr. Mooresville NC 28117

LOCATION / DIRECTIONS Brawley Sch. Rd. TR Southpoint 4th house on right

SUBDIVISION Meck Neck / Clint BLOCK / SECTION 6 LOT # 423B LOT AREA 1.07 Ac. DESIGN FLOW 120gpd * L.T.A.R. .39gpd/ft²

Septic Tank Existing Gallons: STB ____ Date ____

Pump Tank ____ Gallons: PT ____ Date ____

Pump Make ____ Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 1 Linear Feet 100

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

☐ New System ☐ Repair ☒ Expansion System Type I (II) III IV V VI

System Description: 25% Reduction gravity

Repair System Description: 25% Reduction gravity

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 3

☐ Business No. Persons ____

☐ Other No. Employees ____

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Install Drop Box, or D-Box with speed levelers to feed existing bed and new line below.

Comments / Conditions: * 360 gpd total including existing bed

INITIAL SITE SKETCH

See Approved plan from Rollins Soil & Environmental Services, PA.

AS BUILT SKETCH

Install 1-100' line ADS 36 feeding exist Bed then Drop box to new line as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Ronnie Thompson Date 6-1-10

Improvement Permit by: Judy Melville Date 5-28-10

Authorization to Construct by: Judy Melville Date 6-1-10

Installed by: Richard Abernathy

Operation Permit by: [illegible] REHS Date: 8/18/2010

Existing System Inspected by: ____ Date: ____

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant