INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3239-A DATE: 1-28-88

TC: 001-372-33 □ L

SERIAL № 11518

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 9-7-87 All work shall be completed on or before 2-7-9-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 1 Bed 12x75x12" feet

Total Line Length 300 feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well 50" feet

NAME OF OWNER LYLES KENNETH

LOCATION OF PROPERTY 16233 YELLOW JACKET CIR

Comments: 1 Bed 12' x 75' x 12"

J. D. Daniel, RS. Kelly Rundell

Division or Section Head Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11606

File: 3239-A Action: 1

Parcel: 201-372-33 ☐ PC

Location: Yellow Jacket Circle

Subdivision:

Lot: **Block:** **Acres:** .72


Owner: Chalmers William Cook
Address: 1121 Greenwood Cliff
Charlotte, N. C. 28204

Comments:

Described by: William A. Wesbi

Date: 8-11-87

4624242772
154 Yellow Jacket Cr.
LAKE NORMAN Lot 413



***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 8-15%	S PS (U) Terraces	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 7.36" to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 7.36"	S PS U	S PS U	S PS U	S PS U	S Ps U
Restrictive Horizons	S (PS) U 7.36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IUA Cecil-Lilo	Terraces				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U