DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bowlen Const.
APPLICANT:
ADDRESS:
APPLICATION DATE:
DATE EVALUATED:
PROPOSED FACILITY: 4BD. House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 30,303 SF
LOCATION OF SITE: Yellow Jacket Ch. - Cuffman Point - 8 PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	8-9% LS TOP R-R CORNER	0-10	GR / SL (BR) (R)	VFR SS - NP	/BR				
		11-19	SBK / CL	SSSP FR SS - SP	/R				
		20-33	ST. SBK / INCL LG. (R) CL	SSSP MIC FR SS - SP	PS / R				.25
		34-48	FR SBK / SCL	NSSP MIC FR SS - SP.	PS / R	S	NA	NA	.3
2	4-5% LS(S) F-L CORNER	0-9	GR / SL	VFR SS - NP	S / BR				
		10-24	MOD SBK / CL	FR SS - SP	S / R				
		25-34	ST. SBK / LG. INCL - MIC CL	FR S - SP.	S / R				.25
		35-49	FR SBK / CL MIC	FR. S - SP	S / R	S	NA	NA	.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	(R) 16" PPBPS	(F) 16" PPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): Berme on PS / Driveway location
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: Dpowlen
OTHER(S) PRESENT: NONE