DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: L. Barber
ADDRESS: ___ APPLICATION DATE ___
PROPOSED FACILITY: Home ___ PROPOSED DESIGN FLOW (.1949): 360 ___ DATE EVALUATED: 7/14/03
LOCATION OF SITE: Yellow Jacket Dr. - Lot 3 Craftsman Point ___ PROPERTY SIZE: .76
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Low-Terrace NCC L 3-4%	0-11	Silt Loam						.25 .35
		12-23	MSBK / cl						
		24-34	MSBK / hcl	Fi S - SP NEKP					
		35-48	MS SBK / scl	FR SS SP NEKP					
2	Top/Crest L 4-7%	0-14	SBK - scl	Fi SS SP					.25 .55
		15-24	MSBK - hcl	Fi S - SP					
		25-48	MF SBK - cl	FR SS - SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

COMMENTS: ___