PD-195

176531+

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 201236

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4624257514

APPLICANT: KENNETH KOONTZ APPLICANT ADDRESS: 109 LYNNFIELD CT. MOORESVILLE. 28117

SITE ADDRESS: 112 YELLOW JACKET CIRCLE PHONE: ALT. PHONE:

SITE DIRECTIONS: BRAWLEY SCHOOL RD - TR YELLOW JACKET - ON RT

SUBDIVISION: CLDJ SECTION: 6 LOT # 405 LOT AREA: 1.11AC DESIGN FLOW: 480 GPD L.T.A.R.: .36GPD/FT2

Septic Tank 1000 (gal) STB 794 Date 1-25-14
Pump Tank 1000 (gal) PT 283 Date 2-28-14
Pump Make Goulds Model WE0312MU Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 400
Trench Width 36" Max. Trench Bottom Depth 48" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: ~~GRAVITY~~ PUMP 25'/6
Repair System Description: CP PIPES + CONN.
Maintenance Agreement Required: ☐ YES ☑ NO
☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 4
☐ Business No. Persons 8
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: Trench Bottom 48"

INITIAL SITE SKETCH

SEE MICHAEL ATHANAS & ASSOCIATES PLAN

AS BUILT SKETCH

*Installed As Drawn
*IQ4W Installed

The proposed / existing SWIMMING POOL addition does not appear to impact the existing septic system.
**NOTE: Keep Swimming Pool 15 ft from Tanks & Drainfield and 10 ft from supply lines
R.S.
Date: 5-5-14
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 1/27/14 Installed by: R & H

IMPROVEMENT PERMIT by: Date: 1/24/14 OPERATION PERMIT by: Date: 5-2-14

AUTHORIZATION TO CONSTRUCT by: Date: 1/24/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK