4624267540

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 125052 PIN # 4624306585 DATE 7-6-2010

OWNER or APPLICANT Stonebridge Luxury Homes PHONE: Business 704 658-1404 Home: 980 721 5434 Chris

OWNER or APPLICANT ADDRESS P.O. Box 4297 Mooresville, NC 28117

LOCATION / DIRECTIONS Brawley School Rd TR Bunker Way at end

SUBDIVISION The Point 144 BLOCK / SECTION 10 LOT # 1006 LOT AREA DESIGN FLOW 1000 L.T.A.R. .25 - .3

Septic Tank 1500 Gallons: STB 1500 Date 9-20-11
Pump Tank 1500 Gallons: PT 477 Date 8-23-11
Pump Make Gould's Model WE10124 Serial # 1112510
Nitrification Field No Fields 2 No Lines 8 Linear Feet 36 + 333
Trench Width 24" min. Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI
System Description: Pump-LP-Panel Blk LP PPBPS
Repair System Description:
Maintenance Agreement Required ☒ YES ☐ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 5
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply
☐ Private
☐ Public
☒ Community

Comments / Conditions 10/25/11 Tanks Checked

Comments / Conditions 10/27/11 Lines Checked
36ft from House to first line in front
75ft from PT to T w 3ft above 1st line
at lowerfield

INITIAL SITE SKETCH

See Attached plan prepared by Piedmont Design Assoc. PA dated May 21, 2010.

A contract shall be executed between the System Owner & a Management Entity prior to the issuance of an Operation Permit

AS BUILT SKETCH

11/28/11 Set 3ft pressure, float & alarm

The proposed / existing Spa addition does not appear to impact the existing septic system.
**NOTE: The Spa will be in area formerly designated for Pool.
Maria Dotson REHS
Date: 9-22-2011
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 7/8/2010
Improvement Permit by: Maria Dotson REHS Date 7/6/2010
Authorzation to Construct by: Maria Dotson REHS Date 7/8/2010

Installed by: Steve Gordon RS
Operation Permit by: Maria Dotson Date: 11/28/11
Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK